ECAN1000HR
Isolated CAN interface board
User's Manual

Hardware releases 1.0-1.1



Real Time Devices, Inc.

"Accessing the Analog World"®

ECAN1000HR ISOLATED 1 MB/S CAN INTERFACE BOARD USER'S MANUAL

Declaration of Conformity of the ECAN1000HR to the following Directives:

EU EMC directive 89/336/EEC

EU Low Voltage directive 73/23/EEC

using the relevant section of the following EU standards and other normative documents:

EN50081-2: 1995	**Emissions, generic requirements**
-EN55022	Measurement of radio interference characteristics of information technology equipment
EN50082-2: 1995	**Immunity, generic requirements**
-EN61000-4-3	Radio-frequency electromagnetic field, AM modulated
-EN61000-4-6	Radio-frequency common mode, AM modulated
-EN61000-4-2	Electrostatic discharge
-EN61000-4-4	Fast transients

Relevant documents are available upon request from RTD.

Tomi Hänninen
Managing Director
RTD Finland Oy

REAL TIME DEVICES FINLAND OY
LEPOLANTIE 14
FIN-00660 HELSINKI
FINLAND

Phone: (+358) 9 346 4538
FAX: (+358) 9 346 4539

E-Mail
sales@rtdfinland.fi

Website
www.rtdfinland.fi

Revision History

28/11/1991	Release 1.0
15/07/2001	Name of company changed, reformatted

Notice: We have attempted to verify all information in this manual as of the publication date. Information in this manual may change without prior notice from RTD Finland Oy.

Published by
Real Time Devices Finland Oy
Palovartijantie 13-17
FIN-00750 Helsinki
Finland

Copyright 1999-2001 Real Time Devices Finland Oy
All rights reserved
Printed in Finland

PC/XT, PC/AT are registered trademarks of IBM Corporation.
PC/104 is a registered trademark of PC/104 Consortium.
The Real Time Devices Logo is a registered trademark of Real Time Devices.
utilityModule is a trademark of Real Time Devices.
All other trademarks appearing in this document are the property of their respective owners.

TABLE OF CONTENTS

LIST OF ILLUSTRATIONS AND TABLES 6

CHAPTER 1 -INTRODUCTION.....7

Features 7
CAN bus controller.....7
Physical interface 7
Mechanical description 7
Connector description.....8
What comes with your board 8
Board accessories 8
-Application software and drivers
-Hardware accessories
Using this manual.....8
When you need help.....8

CHAPTER 2 - BOARD SETTINGS 9

Factory-configured jumper settings.....10
Base Address jumpers.....11
Interrupt channel.....13

CHAPTER 3- BOARD INSTALLATION 14

Board installation 14
External I/O connections.....16
-Galvanically isolated CAN bus connector
-Galvanically isolated CAN bus termination jumper

CHAPTER 4- HARDWARE DESCRIPTION.....17

SJA1000 CAN bus controller 18
Galvanic Isolation of the CAN bus 18

CHAPTER 5 - BOARD OPERATION AND PROGRAMMING 19

Defining the memory map 19
-SJA1000 Datasheet reprint from Philips
Interrupts 20
What is an interrupt? 20
Interrupt request lines 20
8259 Programmable interrupt controller 20
Interrupt mask register (IMR) 20
End-Of-Interrupt (EOI) Command 21
What exactly happens when an interrupt occurs? 21
Using interrupts in your program 21
Writing an interrupt service routine (ISR) 21
Saving the startup IMR and interrupt vector 23
Common Interrupt mistakes 24

CHAPTER 6 - ECAN1000HR SPECIFICATIONS 25

CHAPTER 7 - RETURN POLICY & WARRANTY 26

LIST OF ILLUSTRATIONS AND TABLES

ILLUSTRATIONS

Fig. 2-1: Board layout showing jumper locations

Fig. 2-2: Base address jumpers

Fig. 2-3: Interrupt jumpers

Fig. 3-1: ECAN1000HR integrated with a PC/104 cpuModule stack

Fig. 3-2: 19" Eurocard rack installation with an integrated PC/104 data Module and EUROCARD cpuModule computer system

Fig. 4-1: ECAN1000HR Block diagram

TABLES

Table 2-1: Factory configured jumper settings

Table 2-2: Base Address jumper settings

Table 3-2: Physical interface connector pinouts of ECAN1000HR

Chapter 1 INTRODUCTION

This user's manual describes the operation of the ECAN1000HR CAN bus Interface board.

Features

Some of the key features of the ECAN1000HR include:

- SJA1000 CAN-network controller, Electrically compatible with the PCA82C200 stand-alone CAN controller chip
- 1 Mb/s maximum datarate (fully programmable)
- Full CAN-functionality 2.0 B
- Extended receive buffer (64 byte FIFO)
- 16 MHz clock frequency
- Galvanically isolated physical interfaces
- I/O mapped host interface using three addresses
- -40 to +85C operational temperature
- +5V only operation
- PC/104 compliant

The following paragraphs briefly describe the major features of the ECAN1000HR. A more detailed discussion in included in Chapter 4 (Hardware description) and in Chapter 5 (Board operation and programming). The board setup is described in Chapter 2 (Board Settings). A full description of the Philps SJA1000 CAN-controller is included in Chapter 5 (Board operation and programming).

CAN bus controller

The ECAN1000HR CAN bus interface is implemented using the Philips SJA1000 controller. This controller supports CAN Specification 2.0. This versatile chip supports standard and extended Data and Remote frames; a Programmable Global Message Identifier Mask; 15 message objects of 8-byte Data Length and a Programmable Bit Rate. This fully integrated chip supports all the functionality of the CAN bus protocol. The internal 64 byte receive FIFO is ideal for block mode data transfer from the CAN controller chip.

Physical Interface

Industrial environments require galvanic isolation and bus filtering to provide reliable data communication and safety. The *galvanivally isolated physical interface* is uses high speed optocouplers and a DC/DC converter. To protect the input from radiated bus noise a specially balanced bus filter is used. The bus connectors conform to the ISO11898 /2 specification. (For more information on CAN bus please visit the CAN in Automation Website at**: http://www.can-cia.de**.)

Mechanical description

The ECAN1000HR is designed on a PC/104 form factor. An easy mechanical interface to both PC/104 and EUROCARD systems can be achieved. Stack your ECAN1000HR directly on a PC/104 compatible computer using the onboard mounting holes.

Connector description

There is a 10-pin interface connector on the ECAN1000HR to directly interface to the galvanivally isolated CAN-networks. This header is compliant with the ISO11892/2 specified pinout.

What comes with your board?

Your ECAN1000HR package contains the following items:

- ECAN1000HR CAN bus interface module
- User's manual

Note: Software and drivers can be downloaded from our website

If any item is missing or damaged, please call Real Time Devices Finland customer service department at the following number: (+358) 9 346 4538.

Board accessories

In addition to the items included in your ECAN1000HR delivery, several software and hardware accessories are available. Contact your local distributor for more information and for advice on selecting the most appropriate accessories to support your system.

- **Application software/drivers QNX**
- **Hardware accessories including IDAN solid aluminium frames for PC/104 based computers**

For more information on IDAN, please visit our websites at the following website addressses: **www.rtdfinland.fi** or **www.rtdusa.com**.

Using this manual

This manual is intended to help you install your new ECAN1000HR card and get it working quickly, whilst also providing enough detail about the board and it's functions so that you can obtain maximum use of it's features even in the most demanding applications. This manual does not cover CAN bus network programming and system design.

When you need help

This manual and all the example programs will provide you with enough information to fully utilize all the features on this board. If you have any problems with installation or use of the board, contact our Technical Support Department (+358) 9 346 4538 during European business hours. Alternatively, send a FAX to (+358) 9 346 4539, or Email to: **sales@rtdfinland.fi.** When sending a FAX or Email request, please include the following information: Your company's name and address, your name, your telephone number, and a brief description of the problem.

Chapter 2 BOARD SETTINGS

The ECAN1000HR CAN bus interface board has jumper settings which can be changed to suit your application and host computer memory configuration. The factory settings are listed and shown in the diagram at the beginning of this chapter.

Factory-Configured Jumper Settings

Table 2-1 below illustrates the factory jumper setting for the ECAN1000HR. Figure 2-1 shows the board layout of the ECAN1000HR and the locations of the jumpers. The following paragraphs explain how to change the factory jumper settings to suit your specific application.

Table 2-1: Factory configured jumper settings (Please, see figure 2-1 for detailed locations)

JUMPER NAME	DESCRIPTION	NUMBER OF JUMPERS	FACTORY SETTING
BASE	Base Addresses	8	300H
IRQ SELECT	Host interrupts	10	5
J34	CAN bus termination	1	Closed



Figure 2-1: ECAN1000HR Board layout showing jumper locations

Base Address Jumpers (Factory setting: 300h)

The ECAN1000HR is I/O mapped into the memory space of your host XT/AT. This board occupies two I/O addresses starting from the base address.

The most common cause of failure when you are first setting up your module is address contention: Some of your computers I/O space is already occupied by other devices and memory resident programs. When the ECAN1000HR attempts to use it's own reserved memory addresses (which are being already used by another peripheral device) erratic performance may occur and the data read from the board may be corrupted.

To avoid this problem make sure you set up the base address by using the ten jumpers marked "BASE". This allows you to choose from a number of different addresses in your host computer I/O map. Should the factory installed setting of 300h be incompatible to your system configuration, you may change this setting to another using the options illustrated in Table 2-2 (overleaf). The table shows the jumper settings and their corresponding values in hexadecimal form. Ensure that you verify the correct location of the base address jumpers. When the jumper is removed it corresponds to a logical "0", connecting the jumper to a "1". When you set the base address of the board, record the setting inside the back cover of this manual

Table 2-2: Base Address Jumper Settings

BASE ADDRESS JUMPER SETTINGS ECAN1000HR

Base address Hex	Jumper Setings A8 A7 A6 A5
200	0 0 0 0
220	0 0 0 1
240	0 0 1 0
260	0 0 1 1
280	0 1 0 0
2A0	0 1 0 1
2C0	0 1 1 0
2E0	0 1 1 1
300	**1 0 0 0**
320	1 0 0 1
340	1 0 1 0
360	1 0 1 1
380	1 1 0 0
3A0	1 1 0 1
3C0	1 1 1 0
3E0	1 1 1 1
0 = JUMPER OFF	**1 = JUM PER CLOSED**

Note: The above table illustrates the settings for the high address bits A8-A5, A9 is always decoded "1".



Fig. 2-2: Base address jumpers illutrating address 300 h

Interrupt channel (Factory setting: IRQ5)

The header connector, shown in Figure 2-3 below, lets you connect the onboard SJA1000 CAN controllers interrupt outputs to one of the interrupt channels available on the host XT/AT bus. If your board has no AT-extension interrupts, IRQ 10-15 are not available.



Fig. 2-3: Interrupt set to IRQ 5.

Note: The ECAN1000HR does not support interrupt sharing! This feature is sometimes regarded as a part of the PC/104 special features. After extensive software and hardware tests we have found that errorfree interrupt performance can not be guaranteed when sharing interrupts.

Chapter 3 BOARD INSTALLATION

The ECAN1000HR CAN bus interface board is very easy to connect to your industrial distributed control system. Direct interface to PC/104 systems as well as EUROCARD boards is possible. This chapter gives step-by-step instructions on how to install the ECAN1000HR into your system.

After completing the installation it is recommended that you use the diagnostic and test software to fully verify that your board is working.

Board Installation

Keep your board in the antistatic bag until you are ready to install it to your system! When removing it from the bag, hold the board at the edges and do not touch the components or connectors. Please handle the board in an antistatic environment and use a **grounded** workbench for testing and handling of your hardware. Before installing the board in your computer, check the jumper settings. Chapter 2 reviews the factory settings and how to alter them. If any alterations are needed, please refer to the appropriate instructions in this chapter. Do however note that incompatible settings can result in unpredictable board operation and erratic response.

General installation guidelines:

- ***Turn OFF the power to your computer and all devices connected to the ECAN1000HR.***
- Touch the grounded metal housing of your computer to discharge any antistatic build-up and then remove the board from its antistatic bag.
- Hold the board by the edges and install it in an enclosure or place it on the table on an antistatic surface.
- Connect the board to the CAN fieldbus using the fieldbus interface header connector J12. Make sure that the orientation of the cable is correct.

Installation integrated with a PC/104 module stack

- Secure the four PC/104 installation holes with standoffs.
- Connect the board to the CAN bus using the CAN header connector J12.



Fig. 3-1: ECAN1000HR integrated in a PC/104 RTD cpuModule stack

3U rack or enclosure installation with a EUROCARD CPU containing an ECAN1000HR

The PC/104 system can be easily inserted into a 19" rack installation using the CPU as a "form factor adaptor". Assemble your PC/104 data modules on an RTD single board EUROCARD computer and install the system in a 19" enclosure. Multiple ECAN1000HR boards can be easily connected to this system. See figure 3-2 below.



Fig 3-2: 19" Eurocard rack installation with an integrated PC/104 dataModule and EUROCARD cpuModule computer system

Galvanically isolated CAN bus connector

Table 3-2 below shows the CAN physical interface connector pinout. This connector is to the right hand side of your board marked J12. The pinout conforms to the ISO 11898/2 standard specification.

PIN number	Function
1	N.C.
2	GND_isolated
3	BUS_L
4	BUS_H
5	GND_isolated
6	N.C.
7	N.C.
8	+5V-isolated
9	GND-isolated
10	N.C.



Table 3-2: Physical interface connector J12 pinout of the ECAN1000HR

Galvanically isolated CAN bus termination jumper

The jumper marked as J34 is the CAN bus termination jumper. Only two termination jumpers should be closed at the endpoints of the CAN bus. Failure to do so may degrade the performance of the bus and it will affect the bus timing characteristics of the CAN bus. The maximum guaranteed drive capability of the CAN bus transceiver is 32 nodes.

Chapter 4 HARDWARE DESCRIPTION

This chapter describes in detail the major features of the ECAN1000HR:

- The Philips SJA1000 CAN bus controller
- Galvanic isolation of the CAN bus



Fig 4-1: ECAN1000HR Block diagram

The CAN bus controller

The SJA1000 CAN bus controller uses a 16 MHz base oscillator. This must be taken into account when performing settings in the CAN bus timing registers that set the baud rate and sampling times of the CAN network.

The SJA1000 CAN controller consists of seven functional blocks. The host interface logic; the Transmit Buffer; the Receive Buffer; the Acceptance Filter; the Bit Stream Processor; the Bit Timing Logic and the Error management logic. A detailed description of these blocks is listed in the detailed component specific datasheet reprinted from Philips Semiconductors.

The SJA1000 internal message FIFO RAM provides storage for 64 message bytes. Each message can vary from one to up to 8 bytes in length. Each message object has a unique identifier and can be configured to either transmit or to receive.

Each message identifier contains control and status bits. A message object with a direction set for receive will send a remote frame by requesting a message transmission. A message set as transmit will be configured to automatically send a data frame whenever a remote frame with a matching identifier is received over the CAN bus. All message objects have separate transmit and receive interrupts and status bits, allowing the CPU full flexibility in detecting when a remote frame has been sent or received.

The SJA1000 also features masking for acceptance filtering. This feature allows the user to globally mask, or "don't care", any identifier bits of the incoming message. This mask is programmable to allow the user to design an application specifical message identification strategy. There are separate global masks for standard and extended frames. The incoming message first passes through the global mask and is then matched to the identifiers in the message objects

Galvanic isolation of the CAN bus

The galvanic isolation of the ECAN1000HR is implemented using the following:

- Optocouplers for reliable data transmission
- DC/DC converter to supply power to the CAN bus and the physical interface circuitry.

The high-speed optocouplers are directly connected to the SJA1000. The optocouplers drive the CAN bus transceiver. A special balanced CAN bus choke is used not only to improve immunity to bus noise, but also to protect the bus transceiver. This choke also reduces the radiated emissions in the range of 30-200MHz.

A 1W DC/DC converter may be used to power other remote devices on the CAN bus. The output power of this converter is isolated up to 1,5 kV peak. A 125mA fuse (green) are used to protect the DC/DC converter.

The jumper marked as J34 is the CAN bus termination jumper. Only two termination jumpers should be closed at the endpoints of the CAN bus. Failure to do so may degrade the performance of the bus or even cause permanent damage to the driver chips. The maximum drive of the transceiver is 32 nodes.

Chapter 5 BOARD OPERATION AND PROGRAMMING

This chapter shows you how to program and use your ECAN1000HR. It provides a complete description of the internal memory map of the chip and a detailed discussion of the internal registers to aid you in programming your CAN controller chip. The full functionality of the ECAN1000HR is described in the attached datasheet reprint from Philips on the SJA1000 CAN controller chip.

Defining the Memory Map

The memory map of the ECAN1000HR occupies 2 bytes of host PC I/O memory space. This 3-byte window is freely selectable by the user as described in *Chapter 2, Table 2-2.* After setting the base address you have access to the internal resources of the SJA1000 CAN controller chip. These resources are described in the next sections reprinted from the SJA1000 chip specific user's manual.

ADDRESS	Description
BASE+00h	ADDRESS
BASE+01h	DATA of ADDRESS
BASE+02h	HARDWARE RESET OF SJA1000

The SJA1000 chip access is multiplexed in such a way that the host must first write to BASE+0 the internal address of the CAN chip and after that perform a write to address BASE+1 with the actual data to be written into the desired memory location. An example is listed below using "C" syntax. (We assume base address is 300H.)

Write 78H to the CAN controller Control byte located in the on-chip address 0.

```
outp(0x300,0x00);
outp(0x301,0x78);
```

Address BASE+02h is a hardware-reset function of the SJA1000. Performing a read or write to this address will cause a hardware reset to the CAN controller. You may need to reset the chip in case of an unrecoverable error in the CAN controller chip.

On the following pages is attached the chip specific user's manual for the SJA1000 CAN controller chip.

INTERRUPTS

What is an interrupt?

An interrupt is an event that causes the processor in your computer to temporarily halt its current process and execute another routine. Upon completion of the new routine, control is returned to the original routine at the point where its execution was interrupted.

Interrupts are a very flexible way of dealing with asynchronous events. Keyboard activity is a good example; your computer cannot predict when you might press a key and it would be a waste of processor time to do nothing whilst waiting for a keystroke to occur. Thus the interrupt scheme is used and the processor proceeds with other tasks. When a key-stroke finally occurs, the keyboard then 'interrupts' the processor so that it can get the keyboard data .It then places it into the memory, and then returns to what it was doing before the interrupt occurred. Other common devices that use interrupts are A/D boards, network boards, serial ports etc.

Your ECAN1000HR can interrupt the main processor when a message is received or transmitted if interrupts are enabled on the ECAN1000HR board. By using interrupts you can write powerful code to interface to your CAN network.

Interrupt request lines

To allow different peripheral devices to generate interrupts on the same computer, the PC AT bus has interrupt request channels (IRQ's). A rising edge transition on one of these lines will be latched into the interrupt controller. The interrupt controller checks to see if the interrupts are to be acknowledged from that IRQ and, if another interrupt is being processed, it decides if the new request should supersede the one in progress or if it has to wait until the one in progress has been completed. The priority level of the interrupt is determined by the number of the IRQ as follows; IRQ0 has the highest priority whilst IRQ15 has the lowest. Many of the IRQ's are used by the standard system resources, IRQ0 is dedicated to the internal timer, IRQ1 is dedicated to the keyboard input, IRQ3 for the serial port COM2, and IRQ4 for the serial port COM1. Often interrupts 2,5 and 7 are free for the user.

8259 Programmable Interrupt Controller

The chip responsible for handling interrupt requests in a PC is the 8259 Interrupt Controller. To use interrupts you will need to know how to read and set the 8259's internal interrupt mask register (IMR) and how to send the end-of-interrupt (EOI) command to acknowledge the 8259 interrupt controller.

Interrupt Mask Register (IMR)

Each bit in the interrupt mask register (IMR) contains the mask status of the interrupt line. If a bit is set (equal to 1), then the corresponding IRQ is masked, and it will not generate an interrupt. If a bit is cleared (equal to 0), then the corresponding IRQ is not masked, and it can then generate an interrupt. The interrupt mask register is programmed through **port 21h**.

End-of-Interrupt (EOI) Command

After an interrupt service routine is complete, the 8259 Interrupt Controller must be acknowledged by writing the value 20h to port 20h.

What exactly happens when an interrupt occurs?

Understanding the sequence of events when an interrupt is triggered is necessary to correctly write interrupt handlers. When an interrupt request line is driven high by a peripheral device (such as the ECAN1000HR), the interrupt controller checks to see if interrupts are enabled for that IRQ. It then checks to see if other interrupts are active or requested and determines which interrupt has priority. The interrupt controller then interrupts the processor. The current code segment (CS), instruction pointer (IP), and flags are pushed onto the system stack., and a new set if CS and IP are loaded from the lowest 1024 bytes of memory.

This table is referred to as the interrupt vector table and each entry to this table is called an interrupt vector. Once the new CS and IP are loaded from the interrupt vector table, the processor starts to execute code from the new Code Segment (CS) and from the new Instruction Pointer (IP). When the interrupt routine is completed the old CS and IP is popped from the system stack and the program execution continues from the point where the interruption occurred.

Using Interrupts in your program

Adding interrupt support to your program is not as difficult as it may seem especially when programming under DOS. The following discussion will cover programming under DOS. Note, that even the smallest mistake in your interrupt program may cause the computer to hang up and will only restart after a reboot. This can be frustrating and time-consuming.

Writing an Interrupt Service Routine (ISR)

The first step in adding interrupts to your software is to write an interrupt service routine (ISR). This is the routine that will be executed automatically each time an interrupt request occurs for the specified IRQ. An ISR is different from other sub-routines or procedures. First, on entrance the processor registers must be pushed onto the stack before anything else! Second, just before exiting the routine, you must clear the interrupt on the ECAN1000HR by writing to the SJA1000 CAN controller, and write the EOI command to the interrupt controller. Finally, when exiting the interrupt routine the processor registers must be popped from the system stack and you must execute the IRET assembly instruction. This instruction pops the CS, IP and processor flags from the system stack. These were pushed onto the stack when entering the ISR.

Most compilers allow you to identify a function as an interrupt type and will automatically add these instructions to your ISR with one exception: most compilers do not automatically add the EOI command to the function, you must do it yourself. Other than this and a few exceptions discussed below, you can write your ISR as any code routine. It can call other functions and procedures in your program and it can access global data. If you are writing your first ISR, we recommend you stick to the basics; just something that enables you to verify you have entered the ISR and executed it successfully. For example: set a flag in your ISR and in your main program check for the flag.

Note: If you choose to write your ISR in in-line Assembly, you must push and pop registers correctly and exit the routine with the IRET instruction instead of the RET instruction.

There are a few precautions you must consider when writing ISR's. The most important is, **do not use any DOS functions or functions that call DOS functions from an interrupt routine.** DOS is not re-entrant; that is, a DOS function cannot call itself. In typical programming, this will not happen because of the way DOS is written. But what about using interrupts? Consider then the following situation in your program: If DOS function X is being executed when an interrupt occurs and the interrupt routine makes a call to the same DOS function X, then function X is essentially being called while active. Such cases will cause the computer to crash. DOS does not support such operations. The general rule is that do not call any functions that use the screen, read keyboard input or any file I/O routines. These should not be used in ISR's.

The same problem of re-entrancy also exists for many floating-point emulators. This effectively means that you should also avoid floating point mathematical operations in your ISR.

Note that the problem of reentrancy exists, no matter what programming language you use. Even, if you are writing your ISR in Assembly language, DOS and many floating point emulators are not re-entrant. Of course there are ways to avoid this problem, such as those which activate when your ISR is called. Such solutions are, however, beyond the scope of this manual.

The second major concern when writing ISR's is to make them as short as possible in term of execution time. Spending long times in interrupt service routines may mean that other important interrupts are not serviced. Also, if you spend too long in your ISR, it may be called again before you have exited. This will lead to your computer hanging up and will require a reboot.

Your ISR should have the following structure:

- Push any processor registers used in your ISR. Most C compiler do this automatically
- Put the body of your routine here
- Read interrupt status register of the SJA1000 chip on your ECAN1000HR board
- Clear the interrupt bit by writing to the SJA1000 CAN controller
- Issue the EOI command to the 8259 by writing 20h to address 20h
- Pop all registers. Most C compilers do this automatically

The following C example shows what the shell of your ISR should be like:

```
/*---------------------------------------------------------------------------
| Function:     new_IRQ_handler
| Inputs:               Nothing
| Returns:      Nothing         - Sets the interrupt flag for the EVENT.
|---------------------------------------------------------------------------*/
void interrupt far new_IRQ_handler(void)
{

        IRQ_flag = 1;           // Indicate to main process interrupt has occurred
        {
        // Your program code should be here
        }
                                // Read interrupt status registers
                                // Clear interrupt on ECAN1000HR
        outp(0x20, 0x20);       /* Acknowledge the interrupt controller. */
}
```

Saving the Startup Interrupt Mask Register (IMR) and interrupt vector

The next step after writing the ISR is to save the "start up"-state of the interrupt mask register and the original interrupt vector you are using. The IMR is located in address **21h**. The interrupt vector you will be using is located in the interrupt vector table which is an array of pointers (addresses) and it is locate din the first 1024 bytes of the memory (Segment 0 offset 0). You can read this value directly, but it is better practice to use DOS function 35h (get interrupt vector) to do this. Most C compilers have a special function available for doing this. The vectors for the hardware interrupts on the XT-bus are vectors 8-15, where IRQ0 uses vector 8 and IRQ7 uses vector 15. Thus if your ECAN1000HR is using IRQ5 it corresponds to vector number 13.

Before you install your ISR, temporarily mask out the IRQ you will be using. This prevents the IRQ from requesting an interrupt while you are installing and initializing your ISR. To mask the IRQ, read the current IMR at I/O port 21h, and set the bit that corresponds to the IRQ. The IMR is arranged so that bit 0 is for IRQ0 and bit 7 is for IRQ7. See the paragraph entitled *Interrupt Mask Register (IMR*) earlier in this discussion for help in determining your IRQ's bit. After setting the bit, write the new value to I/O port 21h.

With the startup IMR saved and the interrupts temporarily disabled, you can assign the interrupt vector to point to your ISR. Again you can overwrite the appropriate entry in the vector table with a direct memory write, but this is not recommended. Instead use the DOS function 25h (Set Interrupt Vector) or, if your compiler provides it, the library routine for setting up interrupt vectors. Remember that interrupt vector 8 corresponds to IRQ0, vector 9 for IRQ1 etc.

If you need to program the source of your interrupts, do that next. For example, if you are using transmitted or received messages as interrupt sources, program it to do that. Finally, clear the mask bit for your IRQ in the IMR. This will enable your IRQ.

Common Interrupt mistakes

Remember that hardware interrupts are from 8-15, XT IRQ's are numbered 0-7. Forgetting to clear the IRQ mask bit in the IMR Forgetting to send the EOI command after ISR code disables further interrupts.

Example on Interrupt vector table setup in C-code:

```
void far _interrupt new_IRQ1_handler(void );          /* ISR function prototype */
#define IRQ1_VECTOR       3                           /* Name for IRQ */
void (interrupt far *old_IRQ1_dispatcher)
        (es,ds,di,si,bp,sp,bx,dx,cx,ax,ip,cs,flags);  /* Variable to store old IRQ_Vector */
void far _interrupt new_IRQ1_handler(void );

/*---------------------------------------------------------------------
| Function:     init_irq_handlers
| Inputs:               Nothing
| Returns:      Nothing
| Purpose:      Set the pointers in the interrupt table to point to
|               our funtions ie. setup for ISR's.
|---------------------------------------------------------------------*/
void init_irq_handlers(void)
{
        _disable();
                old_IRQ1_handler = _dos_getvect(IRQ1_VECTOR + 8);
                _dos_setvect(IRQ1_VECTOR + 8, new_IRQ1_handler);
                Gi_old_mask = inp(0x21);
                outp(0x21,Gi_old_mask & ~(1 << IRQ1_VECTOR));
        _enable();
}

|/*---------------------------------------------------------------------
| Function:     restore do this before exiting program
| Inputs:               Nothing
| Returns:      Nothing
| Purpose:      Restore interrupt vector table.
|---------------------------------------------------------------------*/
void restore(void)
{
        /* Restore the old vectors */

        _disable();

                _dos_setvect(IRQ1_VECTOR + 8, old_IRQ1_handler);
                outp(0x21,Gi_old_mask);

        _enable();
}
```

Chapter 6 ECAN1000HR SPECIFICATIONS

Host Interface

I/O mapped device, occupies 3 bytes
Jumper-selectable base address
8-bit data bus, 16-bit AT bus connector
Jumper selectable XT and AT interrupts

CAN Interfaces

Galvanically isolated transceiver 1 Mb/s datarate
Timing parameters and speed of bus programmable
Balanced CAN bus Choke
Jumper selectable 120 Ohm termination resistors
Transceiver type: Philips 82C251
0.8W 5V isolated output power for other field devices

Connectors

Galvanically isolated CAN bus	90 degree 10-pin header
Host bus	XT/AT PC/104 bus

Electrical

Operating temperature range	-40 to +85 C
Supply voltage	+5V, +-8%
Power consumption	1,0W typical

CE

The ECAN1000HR is CE certified in the IDAN Enclosure System.
Please consult the factory for more information on the system.

Chapter 7 RETURN POLICY AND WARRANTY

Return Policy

If the module requires repair, you may return it to us by following the procedure listed below:

Caution: Failure to follow this return procedure will *almost always* delay repair! Please help us expedite your repair by following this procedure.

1) Read the limited warranty, which follows.

2) Contact the factory and request a Returned Merchandise Authorization (RMA) number.

3) On a sheet of paper, write the name, phone number, and fax number of a technically competent person who can answer questions about the problem.

4) On the paper, write a detailed description of the problem with the product. Answer the following questions:

- Did the product ever work in your application?
- What other devices were connected to the product?
- How was power supplied to the product?
- What features did and did not work?
- What was being done when the product failed?
- What were environmental conditions when the product failed?

5) Indicate the method we should use to ship the product back to you.

- We will return warranty repairs by UPS Ground at our expense.
- Warranty repairs may be returned by a faster service at your expense.
- Non-warranty repairs will be returned by UPS Ground or the method you select, and will be billed to you.

6) Clearly specify the address to which we should return the product when repaired.

7) Enclose the paper with the product being returned.

8) Carefully package the product to be returned *using anti-static packaging!* We will not be responsible for products damaged in transit for repair.

7) Write the RMA number on the outside of the package.

8) Ship the package to:

Real Time Devices Finland Oy

Lepolantie 14

FIN-00660 Helsinki

FINLAND

Limited warranty

Real Time Devices warrants the hardware and software products it manufactures and produces to be free from defects in materials and workmanship for one year following the date of shipment from REAL TIME DEVICES. This warranty is limited to the original purchaser of product and is not transferable.

During the one year warranty period, REAL TIME DEVICES will repair or replace, at its option, any defective products or parts at no additional charge, provided that the product is returned, shipping prepaid, to REAL TIME DEVICES. All replaced parts and products become the property of REAL TIME DEVICES. Before returning any product for repair, customers are required to contact the factory for an RMA number.

THIS LIMITED WARRANTY DOES NOT EXTEND TO ANY PRODUCTS WHICH HAVE BEEN DAMAGED AS A RESULT OF ACCIDENT, MISUSE, ABUSE (such as: use of incorrect input voltages, improper or insufficient ventilation, failure to follow the operating instructions that are provided by REAL TIME DEVICES, "acts of God" or other contingencies beyond the control of REAL TIME DEVICES), OR AS A RESULT OF SERVICE OR MODIFICATION BY ANYONE OTHER THAN REAL TIME DEVICES. EXCEPT AS EXPRESSLY SET FORTH ABOVE, NO OTHER WARRANTIES ARE EXPRESSED OR IMPLIED, INCLUDING, BUT NOT LIMITED TO, ANY IMPLIED WARRANTIES OF MERCHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, AND REAL TIME DEVICES EXPRESSLY DISCLAIMS ALL WARRANTIES NOT STATED HEREIN. ALL IMPLIED WARRANTIES, INCLUDING IMPLIED WARRANTIES FOR MECHANTABILITY AND FITNESS FOR A PARTICULAR PURPOSE, ARE LIMITED TO THE DURATION OF THIS WARRANTY. IN THE EVENT THE PRODUCT IS NOT FREE FROM DEFECTS AS WARRANTED ABOVE, THE PURCHASER'S SOLE REMEDY SHALL BE REPAIR OR REPLACEMENT AS PROVIDED ABOVE. UNDER NO CIRCUMSTANCES WILL REAL TIME DEVICES BE LIABLE TO THE PURCHASER OR ANY USER FOR ANY DAMAGES, INCLUDING ANY INCIDENTAL OR CONSEQUENTIAL DAMAGES, EXPENSES, LOST PROFITS, LOST SAVINGS, OR OTHER DAMAGES ARISING OUT OF THE USE OR INABILITY TO USE THE PRODUCT.

SOME STATES DO NOT ALLOW THE EXCLUSION OR LIMITATION OF INCIDENTAL OR CONSEQUENTIAL DAMAGES FOR CONSUMER PRODUCTS, AND SOME STATES DO NOT ALLOW LIMITATIONS ON HOW LONG AN IMPLIED WARRANTY LASTS, SO THE ABOVE LIMITATIONS OR EXCLUSIONS MAY NOT APPLY TO YOU.

THIS WARRANTY GIVES YOU SPECIFIC LEGAL RIGHTS, AND YOU MAY ALSO HAVE OTHER RIGHTS, WHICH VARY FROM STATE TO STATE.

SERIAL NUMBER:

BASE ADDRESS:

INTERRUPT: